



## JOB SAFETY ANALYSIS

COMPANY/ PROJECT NAME or ID/ LOCATION ( City, State)	DATE August 18, 2015	<input checked="" type="checkbox"/> NEW <input type="checkbox"/> REVISED	PAGE 1 of 2
WORK ACTIVITY (Description) <h1 style="margin: 0;">SCAFFOLDING</h1>			
<b>DEVELOPMENT TEAM</b>	<b>POSITION / TITLE</b>	<b>REVIEWED BY:</b>	<b>POSITION / TITLE</b>
Dave Ruzich	Safety Coordinator		
<b>MINIMUM REQUIRED PERSONAL PROTECTIVE EQUIPMENT ( SEE CRITICAL ACTIONS FOR TASK-SPECIFIC REQUIREMENTS)</b>			
<input type="checkbox"/> REFLECTIVE VEST <input checked="" type="checkbox"/> HARD HAT <input checked="" type="checkbox"/> LIFELINE / HARNESS <input checked="" type="checkbox"/> SAFETY GLASSES	<input type="checkbox"/> GOGGLES <input type="checkbox"/> FACE SHIELD <input type="checkbox"/> HEARING PROTECTION <input checked="" type="checkbox"/> SAFETY SHOES	<input type="checkbox"/> AIR PURIFYING RESPIRATOR <input type="checkbox"/> SUPPLIED RESPIRATOR <input checked="" type="checkbox"/> PPE CLOTHING	<input checked="" type="checkbox"/> GLOVES Cut-resistant <input type="checkbox"/> OTHER Chaps
<b><sup>1</sup>JOB STEPS</b>	<b><sup>2</sup>POTENTIAL HAZARDS</b>	<b><sup>3</sup>CRITICAL ACTIONS TO MITIGATE HAZARDS</b>	
<b>1) Scaffolds</b>	<ul style="list-style-type: none"> <li>Falls</li> <li>Damaged/Broken Equipment</li> <li>Improper Assembly</li> <li>Improper Use</li> </ul>	<ul style="list-style-type: none"> <li>All scaffolds must be erected and used in accordance with 29CFR1926 Subpart L – Scaffolds.</li> <li>Scaffolds must be designed by a qualified person. Qualified means one who, by possession of a recognized degree, certificate, or professional standing, or who by extensive knowledge, training, and experience, has successfully demonstrated his/her ability to solve or resolve problems related to the subject matter, the work, or the project.</li> <li>Scaffolds must be used and inspected in accordance with the manufacturer’s instruction for each specific model and type of scaffold being used.</li> <li>All wheels equipped with locking devices must be locked prior to climbing, all bolts and nuts must be tight, and all cotter pins must be in place and secured before use.</li> <li>All Brieser erected scaffolds must be erected under the supervision of a scaffold competent person.</li> <li>When working off scaffolds that are four ft. or more above a walking/working surface, fall protection or OSHA compliant handrails are required.</li> <li>The scaffold competent person and the qualified person may be the same individual.</li> <li>Newly erected or modified scaffolds must be inspected by the Brieser’s scaffold competent person and by an Qualified person prior to use.</li> <li>Daily pre-use inspections must be conducted by Brieser’s competent person and the scaffold tag must be signed by the scaffold competent person.</li> </ul>	



## JOB SAFETY ANALYSIS

- <sup>1</sup> Each Job or Operation consists of a set of steps. Be sure to list all the steps in the sequence that they are performed. Specify the equipment or other details to set the basis for the associated hazards in Column 2
- <sup>2</sup> A hazard is a potential danger. What can go wrong? How can someone get hurt? Consider, but do not limit, the analysis to: **Contact** - victim is struck by or strikes an object; **Caught** - victim is caught on, caught in or caught between objects; **Fall** - victim falls to ground or lower level (includes slips and trips); **Exertion** - excessive strain or stress / ergonomics / lifting techniques; **Exposure** - inhalation/skin hazards. Specify the hazards and do not limit the description to a single word such as "Caught"
- <sup>3</sup> Aligning with the first two columns, describe what actions or procedures are necessary to eliminate or minimize the hazards. Be clear, concise and specific. Use objective, observable and quantified terms. Avoid subjective general statements such as, "be careful" or "use as appropriate".